## **IFB ADDENDUM #3**

Date: 01/12/2018

IFB No. 18-004-19



Material and/or Service: General Contractor Services: Construction and Installation of an Outdoor

Walk-In Freezer (49'8" x 17'8") for the Vail Unified School District, located at Empire

High School 10701 E Mary Ann Cleveland Way, Tucson, AZ 85747

IFB Due Date: 01/17/2018 Time: 12:00 p.m., Local Time

Opening Location: Vail Education Center

Attention: Tori Gamble, Purchasing Department

13801 E. Benson Highway, Suite B

Vail, Arizona 85641

Please read the following comments and change your response (if applicable). Sign and add addendum in your response to the request for qualifications.

This IFB is amended as follows:

- 1. Do **Davis** Beacon wages apply to this solicitation? **Yes. This project is paid for with Federal funds therefore, David-Bacon wages do apply.**
- 2. See attached drawings (E 1.0) regarding the changes to the electrical specifications referenced in addendum #2.
- 3. The Sheet Urethane called out on FS 5.0 can this be HD polystyrene? (If so, what rating) Whichever product is used must meet an R-28 Value.
- 4. Will Special Inspections be by owner, or by GC? The special inspections will be by the Architect and owner.
- 5. Can you clarify Drain requirements on FS 1.0 #3? This is a general note that would not pertain to the walk-in freezer.
- 6. Referring to FS 1.0, #8. Is there an interior curb at floor level, around the inside perimeter of the new freezer (to prevent any damage to walls from rolling carts, etc.), or is there just curb for the condenser/compressor units (and if so, at which locations)? No interior curbs are required inside the freezer. Curbs are required for each condensing unit on the roof.

Tori Gamble Procurement Analyst Vail Unified School District #20 purchasing@vailschooldistrict.org

Vendor hereby acknowledges receipt of an agreement with the amendment. A signed copy must be returned with the IFB response.

Vendor Name	
Cionachama	Doto
Signature	Date