



IFB ADDENDUM # 2

Date: 01/10/2018

IFB No. 18-004-19

Material and/or Service: General Contractor Services: Construction and Installation of an Outdoor Walk-In Freezer (49'8" x 17'8") for the Vail Unified School District, located at Empire High School 10701 E Mary Ann Cleveland Way, Tucson, AZ 85747

IFB Due Date: 01/17/2018

Time: 12:00 p.m., Local Time

Opening Location: Vail Education Center
Attention: Tori Gamble, Purchasing Department
13801 E. Benson Highway, Suite B
Vail, Arizona 85641

Please read the following comments and change your response (if applicable). Sign and add addendum in your response to the request for qualifications.

This IFB is amended as follows:

1. The due date for this solicitation has been extended to Wednesday January 17, 2018 at 12:00 p.m.
2. There have been some changes to EPA standards that now require adding a condensing unit and evaporator coil to the Empire freezer. See attached revised drawings (FS 1.0 – FS 5.0) per the EPA standards.
3. An addendum number 3 will be posted by the end of business day Friday January 12, 2018 with new specifications regarding the electrical changes needed to support the condensing unit and evaporator coil.
4. What is the thickness of the concrete to be removed for foundations? **6" thick**
5. What is the thickness of the asphaltic concrete to be removed for foundations? **4" thick**
6. What do we do with the fencing and appurtenances still on the slab? **These items will remain in place.**
7. Is Fire protection required in Freezer or Canopy? **No this is not a requirement**
8. The deadline for any additional questions will be January 12, 2018 at 10:00 a.m.

Tori Gamble
Procurement Analyst
Vail Unified School District #20
purchasing@vailschooldistrict.org

Vendor hereby acknowledges receipt of an agreement with the amendment. A signed copy must be returned with the IFB response.

Vendor Name

Signature

Date